



LIEN & PETERSON ARCHITECTS, INC.

619 MENOMONIE STREET
EAU CLAIRE, WI
TELEPHONE 715 835 7500
EMAIL

PO BOX 925
54703
FAX 715 835 1411
ADMIN@2DLP.COM

ADDENDUM NO. 2

Date: Monday, September 19, 2017

Project: Plymouth Congregational United Church of Christ

Project #: 1690

This addendum to the contract documents is issued to modify, explain, or correct the original Drawings and Specifications and is therefore made a part of the Contract Documents now in your possession. Please indicate receipt of Addenda on Proposal. All trades shall review and are responsible for items relating to their work.

SPECIFICATIONS**Section 04 26 13**

Page 2, Part 2-Products, Clay Face Brick, line 16 shall read: "Color and Texture; As selected by Architect, based on samples of grey bricks and blends similar to those manufactured by Hebron Brick Company, 2300 Main Ave, Fargo, ND 58103." Brick are to be Utility size, nominally 4"x4"x12".

Section 09 65 19

Page 1, line 24: Solid Vinyl Floor Tile is the product referred to in the Room Finish Schedule as 'Luxury Vinyl Tile'. This product shall be supplied with a 0.020" urethane wear layer, and an overall thickness of 3mm.

No Vinyl Composition Tile is indicated in the Room Finish Schedule, but it may be substituted for 'sealed concrete' where that finish is indicated.

DRAWINGS**Sheet A301**

There is an unnecessary line and note dividing Room A117.1 from Room A122, the floor finish is LVT1(not Carpet) in both rooms.

END OF ADDENDUM